

STIEBEL ELTRON

Head Office. Unit 4 / 8 Rocklea Drive, Port Melbourne, 3207 Victoria.
Ph 03 96451833 Fax 03 96454366
Freecall 1800153351

STIEBEL ELTRON

Date: 3 November 2009

WATER FILTER SPECIFICATION

The Point of Use water filter for drinking water shall include the following:

1. Filter system:

- a) The unit shall include a Ultra-Filtration system using hollow fiber down to **0.01** micron
- b) The unit shall include a Sediment filter with pore size down to **1** micron
- c) Granular Activated Carbon block with **impregnated silver** is optional, but highly recommended
- d) The unit shall be under sink and wall mounted installation, it must not need electricity, no booster pump, no buffer tank needed during the operation

2. Installation and Fittings

- e) The complete filter unit is ready to use for drinking water and fitting accessories for installation
- f) The unit shall shut off water automatically if cartridges are removed or not inserted properly into its body
- g) The unit's cartridges shall have "swing" function to be able to easily exchange cartridge in small area
- h) The unit shall not require tools for cartridges exchange. It shall have "Push & Click" system for easy cartridge exchange

3. Standards

The unit shall be conforming to WaterMark standard AS 3497.